

PHOTOVOLTAIC CONNECTION-UNDERGROUND SERVICE

DISCONNECT SHOULD BE SPACED FAR ENOUGH FROM METER BASE TO ALLOW SAFE OPENING AND CLOSING OF METER BASE BUT NO MORE THAN 6FT AWAY FROM METER BASE. DISCONNECT MUST BE CLEARLY VISIBLE FROM METER BASE LOCATION.

